

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PRIVATE SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Please see above violations.

Overall conditions are satisfactory at this time.

Email Address(es): krichardson@jaxclassical.org

Violations Comments

Violation #5. Maintenance & Repair
Classrooms 180 and 294 had some water stained tiles on the ceiling. Please have these replaced and make sure there is no active leaks there. Replace by next inspection.
CODE REFERENCE: Maintenance & Repair. 6A-2.0040(3)(b)(c). Buildings shall be kept clean & in good repair, free from hazardous conditions, such as loose or broken floor tiles & boards; loose moldings; loose hanging fixtures, pipes, electric wires; & broken plaster. Furnishings & equipment shall be kept clean & in good repair, free of missing parts & sharp edges.

Violation #21. Solid Waste
Dumpsters drain plug was broken and was not leak proof and pest proof. Please have this replaced by next inspection.
CODE REFERENCE: Solid Waste. 6A-2.0040(9). Garbage, trash, & rubbish shall be collected, stored, & disposed of at a frequency & in a manner that prevents a sanitary nuisance. Wet garbage shall be collected & stored in impermeable, leak proof, fly tight containers pending disposal. Outdoor waste containers must be easily cleanable & serviceable. Waste containers & the storage area shall be cleaned frequently to prevent odors & breeding places for vermin. 468.2.3. A smooth nonabsorbent surface shall be provided for outdoor waste containers.

Inspection Conducted By: Hailey Plowucha (059087)
Inspector Contact Number: Work: (904) 253-1280 ex.
Print Client Name:
Date: 9/18/2024

Inspector Signature:

Handwritten signature of Hailey Plowucha.

Client Signature:

Handwritten signature of the client.